



ଅଧିକ୍ଷକପଦବିଭାଗ
ଗ୍ରାମ୍ୟଜଳଯୋଗାଣପରିଚାଳନାବିଭାଗ
OFFICE OF THE SUPERINTENDING ENGINEER
RURAL WATER SUPPLY & SANITATION DIVISION
BALANGIR

Near R.T.O. Office
Balangir, Odisha-, Pin-767001

☎-06652-232173 (O)
Email: eerwss_blg@nic.
Email: eerwssbalangir@gmail.co

Letter No. 3461 dt. 3-6-25

To

The Manager of Laxmi Vikash Techno school,
Kantabanji

Sub: - Submission of water Sample test report.


Sir,

With reference to above cited subject cited above, please find enclosed the water sample test report conducted at the District Water testing Laboratory, Balangir. The Water sample was collected from the designated source by your authorized personnel, and the analysis has been carried out based on the submitted sample

The detailed test results as per the analysis conducted, are attached herewith in Annexure-A for your reference and necessary action.

Encl: - As above.

Yours Faithfully,



Superintending Engineer
RWS&S Division, Balangir.

Memo

Date

Copy submitted to

1. The Additional Chief Engineer, Balangir for Information and necessary action
2. In-charge, State NABL Lab, RWS&S, Khandagiri, Bhubaneswar
3. The Chief Engineer, RWS&S Bhubaneswar, Odisha for information and necessary action.



Principal
Laxmi Vikash Techno School
Kantabanji

Kalahandi Vikash Charitable Trust


Trustee

Analysis Results

Sl. No.	Block	Gp	Village	Location	Parameter	Unit	Test Method	Result	Permissible Limit (IS: 10500-2012)	Remarks
1	Belpara	Salandi	Ampada	Near banmali petrol pump	pH	-	IS 3025 (Part 11):1983	7.5	6.5-8.5	
					Total Dissolved Solids (TDS)	mg/L	IS 3025 (Part 16):1984	28	2000	
					Turbidity	NTU	IS 3025 (Part 10):1984	0.29	5	
					Chloride (Cl ⁻)	mg/L	IS 3025 (Part 32):1988	48	1000	
					Fluoride (F ⁻)	mg/L	IS 3025 (Part 23):1986	0.29	1.5	
					Total Hardness as CaCO ₃	mg/L	IS 3025 (Part 21):1983	134	600	
					Iron (Fe)	mg/L	IS 3025 (Part 53):2003	0.16	1	
					Alkalinity	mg/L	APHA, 23rd Ed. 2017-2320 B(Titration Method) 2017	32	600	


 27-05-25
 Lab. Assistant

Divisional Laboratory, RWS&S Balangir


 27-05-25
 Lab. Chemist

Divisional Laboratory, RWS&S Balangir


 27-05-25
 Superintending Engineer
 RWS&S Division, Balangir


 Principal
 Kalahandi Vikash Techno School
 Kantabanji

Kalahandi Vikash Charitable Trust
 D. Ray
 Trustee